

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1170072

Product: Cables

Type: AER

Rating: 1x16+25 mm²; 3x(16-120)+(25-95) mm²;
4x(16-25)+(25-35) mm², 0,6/1kV

Ordering firm: A KABLO SANAYİ TİCARET A.Ş.
Orta Mahalle Atayolu Caddesi No:22, Tuzla/İstanbul, Turkey

Manufacturer: A KABLO SANAYİ TİCARET A.Ş.
Orta Mahalle Atayolu Caddesi No:22, Tuzla/İstanbul, Turkey

Trade mark:

The test results are stated in the test-report No.: 605175-01/01 of: 23.01.2017


A sample of the product was found to be in conformity with:
HD 626.1 S1:96+A1:97 (ČSN 347614-1:99), HD 626.2 S1:96 (ČSN 347614-2:00),
HD 626.5D S1:96 (ČSN 347614-5D:01), HD 605.S2:08 (ČSN 347010-82:09)

Other data:

The validity of the certificate is limited to: 31.01.2020

06.02.2017

Prague


Mgr. Miroslav Sedláček
Head of Certification Body

Stamp



605175-01